

Los Angeles Fire Pump

Quick Pre-Inspection Checklist

Use this before your fire pump test.

Takes 5–10 minutes.

1. Fire Pump Room

- Room unlocked
 - No storage in room
 - Lights working
-

2. Fuel or Power

Diesel Fire Pump

- Fuel tank at least **2/3 full**
- No fuel leaks

Electric Fire Pump

- Power is on
 - No tripped breakers
-

3. Fire Pump Controller (Most Common Failure)

- Controller is ON
 - Set to **AUTO**
 - No trouble or warning lights**
-

4. Valves

- Main valve is OPEN
 - Discharge valve is OPEN
-

5. Alarms

- Fire alarm panel shows **NORMAL**

If Any Box Is Unchecked

Your system may **fail inspection**.

Fix issues before test day.

Free Checklist Provided By:

Ace Fire LA – reach us at acefirela.com or call (818) 739-9849

Los Angeles Fire Pump Inspections & Testing

Most failed fire pump tests are caused by low fuel, trouble lights, or closed valves. This checklist helps catch those issues early.

Disclaimer:

This checklist is provided for general guidance only. It is not a substitute for a licensed fire pump inspection or official fire department testing. Completing this checklist does not guarantee your system will pass inspection. Always follow local fire authority requirements and consult a qualified fire protection professional.